HIGHLAND TANKS PTY LTD trading as

ULTRA CLEAR
WASTEWATER TREATMENT SYSTEMS

ACN 093 507 725
PO BOX 1158, MITTAGONG NSW 2575
PHONE: 02 4889 8288 FAX: 02 4889 8566

AERATED WASTEWATER TREATMENT SYSTEM

MODEL ST10
SUITABLE TO DEAL WITH WC'S & ALL WASTE
ON RESIDENTIAL PREMISES

Drawn by : L. TASKER | Design by : D. W. REBBECK

SPECIFICATION FOR
Name
Installation Address
No. of Persons

APPROVED
- 9 NOV 2011
DEPARTMENT OF HEALTH, N.S.W.

Chamber Total Capacity

No.	Capacity	Description
1	2001 Ltrs	Primary Chamber 1
2	1005 Ltrs	Primary Chamber 2
3	1273 Ltrs	Aerobic Chamber 1
4	1273 Ltrs	Aerobic Chamber 2
5	433 Ltrs	Settling Chamber
6	591 Ltrs	Disinfection Pump Chamber









Parts Index

No.	Description
A	Flow Hole Primary 1 to Primary 2
B	Inlet Square
C	Sludge Return Pipe
D	Scum Skimmer
E	Flow Pipe Aeration to Settling Chamber
F	Chlorinator
G	Flow Restrictor
H	Pump Ledge and Pump
I	Air Diffuser Line
J	Media Pack

All internal and sundries supplied and installed by
ULTRA CLEAR WASTEWATER TREATMENT SYSTEMS

UCST10SD 25 Revision 3 08/11/2011

COLLECTION WELLS manufactured by **Highland Concrete Tanks**
PO Box 1158, MITTAGONG NSW 2575 Factory: 17 Drapers Road, BRAEMAR
PHONE: 02 4889 8288 FAX: 02 4889 8566
All Septic Tanks & Collection Wells are manufactured to comply with Australian Standards AS/NZS 1546.1:2008.